

Week 12 Unattended Noise Monitoring Reports

Summary of Weekly Noise Data and Exceedances of Permissible Levels

between 07:00 hours Monday 18 March 2019 and 07:00 hours Monday 25 March 2019




Notes

There were 2 exceedances of the construction noise limits during this week of monitoring at 16 Mary's Terrace. Both exceedances occurred on Friday 22nd March and were due to continuous engine noise and hammering from the site. Cole Park Road had 0 exceedances.

- Measured LAeq,1hr - Averaged noise levels over 1-hour period.
- Measured period LAeq,T - The line shown on the graph follows the averaged Leq level over the relevant assessment period (i.e. Monday 08:00-18:00hrs LAeq,10h, or Saturday 08:00-13:00hrs LAeq,5h). When an exceedance occurs, the noise level over a measured period goes above the Construction Noise Level (CNL) limit.
- Construction Noise Level (CNL) limits.

MP1 - 16 Mary's Terrace: Time History Graph



MP2 - 2C Cole Park Road: Time History Graph

