

Week 9 Unattended Noise Monitoring Reports



Summary of Weekly Noise Data and Exceedances of Permissible Levels


between 07:00 hours Monday 25 February 2019 and 07:00 hours Monday 04 March 2019

Notes

There were 2 exceedances of the construction noise limits during this week of monitoring at 16 Mary's Terrace. The first one (26/02/2019) was not site related (train pass by), however the second one (03/03/2019) was due to construction noise (continuous use of hand tools).

- Measured LAeq,1hr - Averaged noise levels over 1-hour period.
- Measured period LAeq,T - The line shown on the graph follows the averaged Leq level over the relevant assessment period (i.e. Monday 08:00-18:00hrs LAeq,10h, or Saturday 08:00-13:00hrs LAeq,5h). When an exceedance occurs, the noise level over a measured period goes above the Construction Noise Level (CNL) limit.
- Construction Noise Level (CNL) limits.

MP1 - 16 Mary's Terrace: Time History Graph



MP2 - 2C Cole Park Road: Time History Graph

