

Week 41 Unattended Noise Monitoring Reports



Summary of Weekly Noise Data and Exceedances of Permissible Levels


between 07:00 hours Monday 08 October 2018 and 07:00 hours Monday 15 October 2018

Notes

There were 16 exceedances of the construction noise limits during this week of monitoring at 16 Mary's Terrace. These exceedances occurred between 08:00 on Sunday 14th to 01:00 on Monday 15th. There were 2 exceedances of the construction noise limits at Cole Park Road. One exceedance occurred between 13:00 to 14:00 on Saturday 13th, the other occurred between 23:00 to 00:00 on Sunday 14th.

- Measured LAeq,1hr - Averaged noise levels over 1-hour period.
- Measured period LAeq,T - The line shown on the graph follows the averaged Leq level over the relevant assessment period (i.e. Monday 08:00-18:00hrs LAeq,10h, or Saturday 08:00-13:00hrs LAeq,5h). When an exceedance occurs, the noise level over a measured period goes above the Construction Noise Level (CNL) limit.
- Construction Noise Level (CNL) limits.

MP1 - 16 Mary's Terrace: Time History Graph



MP2 - 2C Cole Park Road: Time History Graph

