

Week 30 Unattended Noise Monitoring Reports



Summary of Weekly Noise Data and Exceedances of Permissible Levels

between 07:00 hours Monday 19 July 2021 and 07:00 hours Monday 26 July 2021

Notes

The missing data at the Mary's Terrace position this week was due to the noise monitoring equipment being removed for laboratory calibration. There were 0 exceedances of the construction noise limits at Cole Park Road (Footbridge).

Measured LAeq,1hr - Averaged noise levels over 1-hour period.

- Measured period LAeq,T - The line shown on the graph follows the averaged Leq level over the relevant assessment period (i.e. Monday 08:00-18:00hrs LAeq,10h, or Saturday 08:00-13:00hrs LAeq,5h). When an exceedance occurs, the noise level over a measured period goes above the Construction Noise Level (CNL) limit.
- Construction Noise Level (CNL) limits.

MP2 - Cole Park Road (site boundary): Time History Graph

