

Week 43 Unattended Noise Monitoring Reports



Summary of Weekly Noise Data and Exceedances of Permissible Levels

between 07:00 hours Monday 19 October 2020 and 07:00 hours Monday 26 October 2020


Notes

There were 0 exceedances of the construction noise limits at Mary's Terrace.

There were 0 exceedances of the construction noise limits at Cole Park Road (site boundary location). Gaps in the data at Cole Park Road were due to the absence of site power.

- Measured LAeq,1hr - Averaged noise levels over 1-hour period.
- Measured period LAeq,T - The line shown on the graph follows the averaged Leq level over the relevant assessment period (i.e. Monday 08:00-18:00hrs LAeq,10h, or Saturday 08:00-13:00hrs LAeq,5h). When an exceedance occurs, the noise level over a measured period goes above the Construction Noise Level (CNL) limit.
- Construction Noise Level (CNL) limits.

MP1 - Mary's Terrace Platform 5 gate: Time History Graph



MP2 - Cole Park Road: Time History Graph

